

LAS VIRGENES MUNICIPAL WATER DISTRICT
Calabasas, California


Saddle Peak and Cordillera Tank Rehabilitation Design RFP ADDENDUM NO. 1

June 6, 2018

Scope Revision & Clarification:

Consultant scope shall include a seismic analysis of each tank, in accordance to the latest industry guidelines and standards of practice. If the results of the analysis indicate that seismic mitigation measures are required, then design for the seismic retrofit items would be negotiated with the district as an additional cost.

If there are any questions regarding the intent of this revision please contact me directly at colinger@lvmwd.com or 818-251-2163.



Coleman Olinger, P.E.,
Project Manager, LVMWD

Attachments: None