

LAS VIRGENES MUNICIPAL WATER DISTRICT
Request for Quotes: Generator Preventative Maintenance
Notice to Potential Vendors
ADDENDUM NO. 1
March 8, 2021

To: Potential Vendors

The following clarifications, revisions, replacements, additions, and/or deletions shall be made a part of the above-referenced request for quotes.

This Addendum contains the following supplemental information to prospective vendors:

1. Supplemental Information: Additional information regarding stationary backup generators is provided in this addendum.

By: *Doug Anders*
Doug Anders, Administrative Services Coordinator

ACKNOWLEDGEMENT TO BE INCLUDED WITH PROPOSAL:

I have read the entirety of Addendum No. 1.

Signed: _____ Date: _____

LVMWD STANDBY GENERATOR LIST

HEADQUARTERS FACILITY

| | |
|---------------------|--|
| Engine: Detroit | Generator: Spectrum |
| Eng M/N: 81637416 | Equip M/N: 750D560 |
| Eng S/N: 16VF013437 | Equip S/N: 368049 |
| Year: 1996 | Rated KW: 750 938KVA 480 Volts |
| 12,000 Fuel Tank | Run Time: 235 hrs. 100% Load |
| Tier 0 | |

Lift Station #1

| | |
|---------------------|---|
| Engine: Detroit | Generator: Electro Motion |
| Eng M/N: 7123-7005 | Equip M/N: 500FDC43 |
| Eng S/N: 12VA305422 | Equip S/N: AL7994998 |
| Year: 1977 | Rated KW: 250 312 KVA 240/480 Volts |
| 1,000 Fuel Tank | Run Time: 50 hrs. 100% Load |
| Tier 0 | |

Lift Station #2

| | |
|----------------------|---|
| Engine: Detroit | Generator: Electro Motion |
| Eng M/N: 7123-7305 | Equip M/N: 680FDC4327AAWR55 FDC |
| Eng S/N: 12VA-030833 | Equip S/N: 1 7994999 |
| Year: 1977 | Rated KW: 350 438 KVA 480 Volts |
| 1,000 Fuel Tank | Run Time: 42 hrs. 100% Load |
| Tier 0 | |

Rancho Farm Building

| | |
|---------------------|---|
| Engine: Caterpillar | Generator: AC Generator |
| Eng M/N: D343 | Equip M/N: |
| Eng S/N: 62B12698 | Equip S/N: A38433 UD |
| Year: 1977 | Rated KW: 250 313 KVA 480 Volts |
| 1,000 Fuel Tank | Run Time: 50 hrs. 100% Load |
| Tier 0 | |

Cornell Pump Station

| | |
|--------------------|---|
| Engine: Mitsubishi | Generator Generac |
| Eng M/n: OA7642 | Equip M/N: 2503110100 |
| Eng S/N: | Equip S/N: 2067783 |
| Year: 2002 | Rated KW: 20 25 KVA 277/480 Volts |
| Natural Gas Fuel | |

Portable (Small Blue)

| | |
|------------------------|---|
| Engine: Caterpillar | Generator: Marathon |
| Eng M/N: 3208 | Equip M/N: 440FDR8016GG-B663W |
| Eng S/N: 30A00907 | Equip S/N: NL-3097176 |
| AQMD Permit #: D-18100 | Rated KW: 125 156 KVA 480 Volts |
| Year: 1993 | Run Time: 25 hrs. 100% Load |

250 Fuel Tank
Tier 0

Rancho Portable

Engine: Cummins
Eng M/N: NTA-855-G2
Eng S/N: 30345421
AQMD Permit #: D-85140
Year: 1994
250 Fuel Tank
Tier 0

Generator: Onan
Equip M/N: 300DFCB
Equip S/N: E940541852
Rated KW: 300 375 KVA 277/480 Volts
Run Time: 11 hrs. Run Time 100% Load

Tapia Caterpillar #1

Engine: Caterpillar
Eng M/N: D399
Eng S/N: 35B5360
Year: 1982
4,000 Fuel Tank
Tier 0

Generator: Kato
Equip M/N: 900-697361111
Equip S/N: 82842-1
Rated KW: 900 1125 KVA 4160 Volts
Run Time: 21 hrs. 100% Load

Tapia Caterpillar #2

Engine: Caterpillar
Eng M/N: D399
Eng S/N: 35B5361
Year: 1982
4,000 Fuel Tank
Tier 0

Generator: Kato
Equip M/N: 900-697361111
Equip S/N: 82842-2
Rated KW: 900 1125 KVA 4169 Volts
Run Time: 21 hrs. 100% Load

Tapia Waukesha

Engine: Waukesha
Eng M/N: L5792DS14
Eng S/N: 398961
Year: 1988
4,000 Fuel Tank
Tier 0

Generator: Kato
Equip M/N: A243480000
Equip S/N: 95066
Rated KW: 900 1125 KVA 2400/4160 Volts
Run Time: 21 hrs. 100% Load

Westlake Filter Plant

Engine: Caterpillar
Eng M/N: 3408
Eng S/N: 78Z03102
Year: 1989
1,000 Fuel Tank
Tier 0

Generator: Caterpillar
Equip M/N: SR4
Equip S/N: 6DA02015
Rated KW: 400 500 KVA 480 Volts
Run Time: 28 hrs 100% Load

Westlake Pump Station

Engine: Caterpillar
Eng M/N: 3512C
Eng S/N: 2YBD00452
Year: 2016
7,500 Fuel Tank
Tier 2

Generator Caterpillar
Equip M/N:
Equip S/N:
Rated KW 1500 1875 KVA 480 Volts
Run Time: 72hrs 100% Load

LV 2 pump station

Engine: John Deere
Eng M/N: 16068HF285
Eng. S/N: PE6068L1105522
Year: 2010
200 Fuel Tank
Tier 3

Generator Marathon
Equip M/N 431PSL62021
Equip S/N:
Rated KW 155
Run Time: 17 hrs. 100% Load

Stunt Rd Pump Station

Engine: Kubota
Eng M/N: 1Z482-E3B
Eng S/N:
Year:2017
25 Fuel Tank
Tier 4

Generator Multiquip
Equip M/N DA-7000SSA2
Equip S/N 5757275
Rated KW 7 KVA 120/240 Volts
Run Time: 36Hrs 100% Load

END OF ADDENDUM #1