

# Joint Powers Authority – Las Virgenes Municipal Water District

## Screw Conveyors and Liners Request for Bids

### Addendum No. 1

Notice is hereby given to firms that the Request for Bids for Screw Conveyors and Liners has been modified as hereinafter set forth. This Addendum No. 1 shall take precedence over the original Request for Bids. Contractor firms are responsible for reading this addendum in its entirety. The District expects the firm to provide their expertise when constructing their bids.

The following clarifications, revisions, replacements, additions, and/or deletions shall be made part of the above reference document.

#### 1. CLARIFICATIONS

- a. Assume all screws are shaftless, 8620 steel, and composed of two sections welded together (“double bar”), as detailed in Attachment A – Shaftless Screw Sections. *NOTE: Screws being shaftless overrides record drawings. Bid all screws as if shaftless.*

#### 2. REVISIONS

- a. A total of 3 instances incorrectly size the Xylethon liner as 4” wide rather than 48”:
  - i. Page 4 of 6, *Bid Form-Schedule*
  - ii. Page 2 of 2, *Bid Scope & Specifications*
  - iii. Page 2 of 2, *Bid Scope & Specifications*.All liners bid under this contract shall be 48” wide.

#### 3. ADDITIONS

- a. In *Bid Scope & Specifications*, Additional Conditions, Item 5. Warranty should read “A published warranty from the manufacturer shall be submitted with bid stating ~~the~~ **a minimum of 1 year** warranty period for the screw conveyor to be manufactured. [...]”
- b. Include Attachment A – Shaftless Screw Sections.
- c. Include Attachment B – 2019 Bin Feed Screw Replacement Record Drawing.
- d. Include Attachment C – Custom Conveyor Corp. Metering Bin Record Drawings.  
Include Attachment D – PURAC record drawing example. All screws not included in Attachment B or Attachment C, are original screws by PURAC from when the facility was constructed in the early 90s. These drawings include minimal details and specifications, as shown in the example. For bidding purposes, please utilize the dimensions provided in the bid schedule, and the standards and assumptions stated as part of this addendum.

#### 4. DELETIONS

- a. The following line items are removed from this bid: 8, 17, 18, 19, 20, AND 21.