

**LAS VIRGENES MUNICIPAL WATER DISTRICT
Reservoir No. 2 Improvement Project 2014**

Notice to Planholders

**ADDENDUM NO. 1
September 19, 2014**

To: All Planholders of Record

Notice is hereby given to prospective bidders that the Plans and Specifications for the Reservoir No. 2 Improvement Project 2014 have been modified as hereinafter set forth. This Addendum No. 1 shall form a part of the Contract Documents and take precedence over the original Contract Documents.

Bidder shall acknowledge receipt of this Addendum No. 1 in the space below and by completing the acknowledgement on page 1 of the proposal. This page shall be attached to the proposal.

By:  _____
Eric Schlageter, P.E. Associate Engineer

ACKNOWLEDGEMENT TO BE INCLUDED WITH SEALED PROPOSAL:

I have read five pages for Addendum No. 1 including (pages 1-3, revised bid schedule sheet 5A, and Exhibit A attached hereto.

Signed: _____

Date: _____

The following clarifications, revisions, replacements, additions, and/or deletions shall be made a part of the above-referenced contract documents.

Revisions

1. Proposal, Bid Schedule Sheet 5 of the Contract – Replace the Proposal Sheet 5 with revised Proposal sheet 5A (attached). Bid Item No. 2 – Asbestos Pipe Removal and Disposal has been revised to provide an estimated quantity and change to the unit of measurement for payment. In addition the square footage of Bid Item No. 4 – Geomembrane Liner and Geotextile Fabric has been increased to allow for 3% of slack in the material required during installation.
2. Measurement and Payment Page 01025-2, 1.6 BID ITEM 2 – ASBESTOS REMOVAL AND DISPOSAL, B. Measurement: shall be replaced with the following;

“Measurement: Measurement shall be based per pound of asbestos pipe removed and disposed of per the contract specifications. Original delivery tickets shall be provided to the District Representative at the end of each day. The District Representative will create a chronological spreadsheet of the quantities and reconcile them with the Contractor after each weekly progress meeting. Requests for payment shall only include quantities that have been reconciled. The estimated quantity is solely provided as an estimate for bidding purposes. Payment will only be paid for the pounds of asbestos removed based on the unit price per pound and will only be paid if used.”

Clarifications / Response to Questions

1. A request was made for the contact at Baker Tanks that has been working with the Engineer for the temporary tank. Contact information is as follows:

Phil Caudle
Inside Sales Representative
5500 Rawlings Ave.
South Gate, CA 90280
Cell (562) 305-7249
Office (562) 904-3680

2. A request was made for providing the site location that the silt / sediment would be trucked to and spread by the contractor. The site is located within the District's Rancho facility. An exhibit showing the spreading field location and distance from LVMWD headquarters has been provided. (See attached Exhibit A)
3. Question: Can the residual water remaining in the reservoir be used to fill the 60,000 gallon temporary storage tanks?

Answer: It is the Contractors methods and means on how to dispose of the residual water. The District will allow the residual water to be pumped into the temporary storage tanks however the water must be clean and clear of silt / sediment. The definition of what is acceptable as clean and clear water will be directed by the District's representative.

END OF ADDENDUM #1

Eric Schlageter, P.E.

Associate Engineer / Project Manager

**PROPOSAL
TO
LAS VIRGENES MUNICIPAL WATER DISTRICT
FOR THE CONSTRUCTION OF
RESERVOIR # 2 IMPROVEMENTS**

Name of Bidder: _____

Business Address: _____

Phone No.: _____

The site of the work to be constructed and referred to herein is in the County of Los Angeles, California.

The work is to be in accordance with the specifications and contract documents and as shown on plans therefore entitled: Reservoir # 2 Improvements.

TO THE GOVERNING BOARD OF LAS VIRGENES MUNICIPAL WATER DISTRICT.

In compliance with your notice inviting sealed proposals (bids) and other documents, the undersigned bidder proposes to perform the work and in a workmanlike manner, in strict conformity with the plans and specifications and other contract documents, including Addenda Nos. ^[____], ^[____], and ^[____], on file in the office of the Secretary of the District for the contract unit prices herein.

ITEM #	ITEM DESCRIPTION	EST. QUANTITIES	UNIT	UNIT PRICE	SUBTOTAL
1	RESERVOIR DEWATERING		LS		
	SEDIMENT REMOVAL AND DISPOSAL	4,420	CY		
2	ASBESTOS PIPE REMOVAL AND DISPOSAL (ALLOWANCE)	5,000	LBS		
3	SITE WORK FOR SITE CLEARING& GRUBBING, SLOPE CONSTRUCTION & STABILIZATION, AND GRADING	NA	LS		
4	GEOMEMBRANE LINER & GEOTEXTILE FABRIC	94,760 (3% SLACK INCLUDED)	SF		
5	ASPHALT REPAVEMENT	390	TON		
6	TEMPORARY PIPING AND STORAGE TANKS	NA	LS		
7	PRV VALVE REPLACEMENT AND VAULT MODIFICATIONS	NA	LS		
8	SHADE BALLS (OPTIONAL)	107,000	SF		
9	BASE LUMP SUM BID	NA	LS		
	TOTAL PROJECT COST				

EXHIBIT 'A'



US 101

LVMWD HQ DRIVEWAY

RESERVOIR NO. 2

LVMWD HQ CAMPUS

Lost Hills Rd

APPROXIMATE DISTANCE = 4110 FT

RANCHO LAS VIRGENES ACCESS GATE

RANCHO LAS VIRGENES COMPOSTING FACILITY

Las Virgenes Rd

SILT / SEDIMENT SPREADING SITE

Las Virgenes Municipal Water District is not responsible for the accuracy of this presentation. This presentation is for illustrative purposes only. Verify the physical location of all property lines, water lines and ancillary information prior to use.

Sources: Esri, DeLorme, HERE, USGS, Intermap, increment P Corp., NRCAN, Esri Japan, METI, Esri China (Hong Kong), Esri (Thailand), TomTom